



TEST REPORT

No.: AJFTS26007427R01_EN

Date: Sep 14,2026

Page 1 of 6

Cool Room Master Pty Ltd

75 south terrace, wingfield, SA 5013, Australia

Sample Description : EPS Sandwich Panel
Color : White
Thickness : 50mm
Density : 16kg/m³
Style/Item No. : /

The above sample(s) data and information was / were submitted and identified on behalf of the client. SGS is not responsible for the authenticity, integrity and results of the data and information and / or the validity of the conclusion arising therefrom. Results apply to the sample as received.

Sample Receiving Date : Sep 02,2026
Testing Period : Sep 02,2026 to Sep 10,2026
Test Required : AS/NZS 1530.3:1999 Methods for fire tests on building materials, components and structures, Part 3: Simultaneous determination of ignitability, flame propagation, heat release and smoke release.
Test result(s) : See attached sheet

Signed for and on behalf of
SGS-CSTC Standards Technical Services Co., Ltd Anji Branch

Eva

Eva Zhang
Approved signatory



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <https://www.sgs.com/en/Terms-and-Conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.
Attention: To check the authenticity of testing /inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com
No. 301, Sunlight Road, 2 Block, Sunlight Industry Zone, Anji County, Zhejiang Province, China 313300 t (86-572) 5018825 f (86-572) 5018829 www.ssgsgroup.com.cn
中国·浙江·安吉县阳光工业园二区阳光大道301号 邮编: 313300 t (86-572) 5018825 f (86-572) 5018829 sgs.china@sgs.com

Member of the SGS Group (SGS SA)



TEST REPORT

No.: AJFTS26007427R01_EN

Date: Sep 14,2026

Page 3 of 6

- 1) Where some of the specimens do not ignite, means and standard errors for smoke release shall be reported separately for those specimens that ignite and those that do not ignite. The higher of the two values shall be reported as the smoke released for the material or component. If the higher value applies to a non-ignition case, this fact shall be reported.
- 2) Where not all specimens ignite, indices for smoke developed shall be determined separately for those specimens that ignite and those specimens that do not ignite. The index allotted shall be based on the worst result.

Regulatory Indices:

Items	Regulatory Indices
Ignitability index (Range 0 to 20)	0
Spread of flame index (Range 0 to10)	0
Heat evolved index (Range 0 to 10)	0
Smoke developed index (Range 0 to 10)	4

Supplementary Observations:

- (a) Number of specimens tested: 6
(b) The number of specimens that ignite: 0
(c) Where flashing was encountered, and ignition was based on a 10-second flash: No
(d) The number of specimens did emit a radiation intensity rise of 1.4kW/m²: 0
(e) Any observations: color changed
(f) Others: None



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <https://www.sgs.com/en/Terms-and-Conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.
Attention: To check the authenticity of testing /inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com
No. 301, Sunlight Road, 2 Block, Sunlight Industry Zone, Anji County, Zhejiang Province, China 313300 t (86-572) 5018825 f (86-572) 5018829 www.ssgsgroup.com.cn
中国·浙江·安吉县阳光工业园二区阳光大道301号 邮编: 313300 t (86-572) 5018825 f (86-572) 5018829 sgs.china@sgs.com

Member of the SGS Group (SGS SA)